



IGORR IV MAY 23 - 25, 1995

GALTINBURG, TN, USA

FISSION PRODUCT RELEASE FROM THE
MOLTEN RESEARCH REACTOR CORE, FRM-II

H. J. DIDIER SIEMENS AG (KWU)

I. **Agenda**

1. Background for the investigations
 2. radiological design basis accident.
 3. activity inventory in the fuellement
 4. development of the accident
 5. radiation exposer in the environment
- 5.1 design basis accident
- 5.2 whole core (beyond design)

II. **Main aspects**

ad 1

- main assumption for realasation of the FRM II-project:
minimizing of nuclear risks,
political and social acceptance
- safety report and independant expert's reports
- accident analyses

ad 2

- radiological design basis accident = postulation of 15 (out of 113) plates of the core melting under water
- defect on one plate, influence to the neighbouring plates, safety factor 5 mounts to 15 plates = 13 %
- beyond design accident on request of the licensing body: Melting of the whole core under water

(ref. Fig 1 and 2)

ad 3

- calculation of the relevant fission products in the melt (ref Fig 3)

ad 4

- barriers for fission products release
 - fuel - water
 - water - reactor hall
 - reactor hall - environment
- retaining release factors
- fission product release via the ventilation stack (ref Fig 4 and 5)

ad 5.1

- radiation exposer design basis accident, doses for organs and effective dose far below limiting value of 50 mSv (ref Fig 6)

ad 5.2

- core melting under water, building tight, low pressure ventilation system with filters in operation
- effective doses at the plant fence approx. 11 mSv for adults respectively approx. 13 mSv for children.
- effective doses without low pressure ventilation system without filters, building closed, release only by leakages:
approx 12 mSv adults
approx. 17 mSv children


Result:

protection measures against emergencies not necessary in this cases, if it can be realized, that the core stays in the pool under water for all circumstances (ref fig 7 and 8)

III Figures

- 1.) reactor building, + 11,70 m**
- 2.) reactor main pool, Storage pool primary, cooling system**
- 3.) fission product inventory**
- 4.) principle flow sheme for fisssion product**
- 5.) release factors molten core under water**
- 6.) effective doses in mSv for design basis accident**
- 7.) effective dose dependent to the distance, melting of whole core under water, adults**
- 8.) effective dose dependent to the distance , melting of whole core under water, children**

UJA - REAKTORGEBAUDE




New Munich Research Reactor FRM-II
 Reactor Building, Horizontal Section, + 11.70 m

Fig. 1

fission groups	fission	activity inventory whole core
noble gas	Kr 85 Kr 85m Kr 87 Kr 88 Kr 89 Xe 133 Xe 133m Xe 135 Xe 135m Xe 137 Xe 138	1,47 E + 13 *) 7,81 E + 15 1,58 E + 16 2,23 E + 16 2,83 E + 16 4,11 E + 16 1,22 E + 15 3,89 E + 15 6,99 E + 15 3,67 E + 16 3,85 E + 16
Halogene	Br 83 Br 84 Br 85 I 131 I 132 I 133 I 134 I 135	3,30 E + 15 6,25 E + 15 7,73 E + 15 1,76 E + 16 2,69 E + 16 4,14 E + 16 4,66 E + 16 3,85 E + 16
Cäsium/Rubidium	Rb 88 Rb 89 Cs 134 Cs 137 Cs 138	2,25 E + 16 2,93 E + 16 2,51 E + 13 1,20 E + 14 4,14 E + 16
Tellur/Ruthen	Te 131 Te 132 Ru 103 Ru 106	1,59 E + 16 2,65 E + 16 1,14 E + 16 2,33 E + 14
Strontium	Sr 90	1,15 E + 14
Aktiniden	Pu 238 Pu 239 Pu 240 Cm 242	2,98 E + 10 2,47 E + 09 8,44 E + 08 9,99 E + 07

relevant fission product inventory
20 MW, 50 full powerdays



description of abbreviations

- f_1 = prompt release into pool water
- f_{2p} = prompt release into reactor hall
- f_{2v} = delayed release via evaporation
- a = part of evaporation not taken by the pool suction system
- l_F = off gas rate
- l_U = circulation rate
- p = plate out rate
- A_H/A_{BW} = activity concentration in reactor hall and pool water
- DF_U/DF_F = retain factors of ventilation systems

principle flow scheme for fission product releases

Release factor, molten core under water

fission groups	release factor melt / water (f1)	retaining factor water / air (f2)	release fraction f1 * f2
	1,0	1,0	1,0
Halogene	0,75	$5 \cdot 10^{-4}$	$3,8 \cdot 10^{-4}$
Cäsium	0,25	$1 \cdot 10^{-5}$	$2,5 \cdot 10^{-6}$
	$1 \cdot 10^{-3}$	$1 \cdot 10^{-5}$	$1,0 \cdot 10^{-8}$

Fig. 5

	maximum dose (mSv) in the surrounding				limiting values with regard to § 28, Abs. 3 StrlSchV (mSv)
	up to 2000 m		more than 2000 m		
	children	adults	children	adults	
Bladder	1,41	1,18	0,41	0,34	150
Breast	1,97	1,64	0,57	0,47	150
Upper intestine	1,39	1,16	0,40	0,34	150
Lower intestine	1,32	1,10	0,38	0,32	150
Small intestine	1,35	1,13	0,39	0,33	150
Brain	1,85	1,54	0,54	0,45	150
Skin	2,82	2,56	1,11	1,01	300
Testicles	1,63	1,36	0,47	0,39	50
Bone - Surface	2,23	1,86	0,65	0,54	300
Liver	1,48	1,24	0,43	0,36	150
Lungs	1,65	1,37	0,48	0,40	150
Stomach	1,51	1,26	0,44	0,36	150
Spleen	1,51	1,25	0,44	0,36	150
Suprarenal gland	1,41	1,17	0,41	0,34	150
Kidneys	1,51	1,26	0,44	0,36	150
Ovaries	1,28	1,07	0,37	0,31	50
Pancreas	1,34	1,12	0,39	0,32	150
Red bone marrow	1,47	1,23	0,43	0,36	50
Thyroid	1,93	1,61	0,63	0,48	150
Thymus	1,64	1,37	0,48	0,40	150
Uterus	1,26	1,05	0,36	0,30	50
Effective dose	1,68	1,40	0,49	0,41	50

effective doses for design basis accident

Fig. 6

FRM-II: effective dose dependent to the distance, melting of whole core under water




Fig. 7

FRM-II: effective dose dependent to the distance, melting of whole core under water

