



Australian Government

Ansto

Nuclear-based science benefiting all Australians

Early Operational Experience of the Cold Neutron Source on OPAL Reactor

Weijian Lu


Australian Nuclear Science and Technology Organisation

October 2009

The OPAL Reactor

- 20 MW multi-purpose research reactor
- Compact core (MTR-type fuel)
- Light water cooled and moderated
- Heavy water reflected
- Radiopharmaceutical Production
- Neutron Beam Research

The OPAL Reactor




Important Contract Requirements Fulfilled

- 20 litres of single phase liquid deuterium at below 25 K
- Cryogenic power specification – 5 kW
- A standby mode – reactor operating at full power without cryogenic cooling
- Cold neutron flux at reactor face (\sim low 10^{10} $\text{n}\cdot\text{cm}^{-2}\cdot\text{s}^{-1}$) and through neutron guides (\sim mid 10^9 $\text{n}\cdot\text{cm}^{-2}\cdot\text{s}^{-1}$)



An International Project

- **INVAP, Argentina** – overall design, project management, CNS process systems
- **PNPI, Russia** – In-pile (vacuum containment and thermosiphon), deuterium gas
- **Air Liquide, France** – helium cryogenic system
- **Mirrortron, Hungary** – neutron guides


Mechanical Design






Thermosiphon Model





Thermosiphon




Moderator Chamber with Displacer (AlMg5)



MCNP 3-D Model



Timeline




Heat Load Measurement

- Heat load measured by steady state helium thermal balance => 4 kW
- Excellent agreement between measurement and theoretical prediction ($\Delta < 100$ W)
- Single phase moderator verified
- (See conference proceeding for details)


Heat Load vs Reactor Power

Measured Heat Load on the CNS In-pile by Cryogenic Helium Thermal Balance
Linear fits indicate nuclear heat load (W/MW) by the slope and non-nuclear heat load by the offset (W)



Single-Phase Verified

LD2 Heat Load



Flux Contract Performance

Performance Acceptance Criteria (RF = reactor face) (NGH = neutron guide hall)	OPAL measured flux (20 MW equiv) (ϕ in n/cm ² /sec)
Thermal neutron flux at RF for TG4 [1]	4.0×10^{10}
Thermal neutron flux in NGH for TG1(TG3) [1]	$3.3 (2.8) \times 10^9$
Cold neutron flux at RF for CG4 [2]	2.5×10^{10}
Cold neutron flux in NGH for CG1(CG3) [2]	$5.9 (6.4) \times 10^9$

[1] E < 100 meV

[2] E < 10 meV

Operation Issues (positive)

- Standby Operation (SO) mode and Normal Operation (NO) mode at full reactor power
- Two way transition
- SO mode greatly enhances reactor availability – hot commissioning on time made possible
- CNS safety control – 30-minute fast LD2 evaporation manoeuvre after CNS trip to beat xenon poison-out

Operation Issues (negative)

- Repeated cryogenic system failures affecting CNS availability
 - Turbine and compressors
 - Mechanically demanding
 - Sensitive to process purity
- Complex logic in the protection system
 - Preventing undesirable pressure and temperature transients
 - CNS specialist intervention often required