



Replacement of Heat Exchanger

WOOTAEK LEE

HANARO Management Division

2025.06.18

Replacement of Heat Exchanger

CONTENTS

- ▶ **01** Introduction
- ▶ **02** Reflector System Overview
- ▶ **03** Preparation and Set-up
- ▶ **04** Replacement Operation
- ▶ **05** Results
- ▶ **06** Conclusion

Introduction

1



Introduction

» HANARO

High-Flux Advanced Neutron Application Reactor


- ✓ First criticality on 8 Feb. 1995
- ✓ 30MWth(Design Power)
- ✓ Primary Coolant is light water
- ✓ Reflector uses heavy water
- ✓ 32 Fuel assemblies are loaded
- ✓ 28 days of operation period
- ✓ Multi-purpose Research Reactor



Introduction

» General Features of HANARO

Type	Open-tank-in-pool
Power	30 MW _{th}
Coolant	Light water
Reflector	Heavy water
Fuel Materials Enriched	U ₃ Si, 19.75%
Absorber	Hafnium
Reactor Building	Confinement
Max Thermal Flux	4x10 ¹⁴ n/cm ² s
Typical Flux at Port Nose	2x10 ¹⁴ n/cm ² s
7 Horizontal Ports & 36 Vertical Holes	
Vertical Hole for Cold Neutron Source	
Operation Cycle	28 days@5 weeks



Introduction

» Need for replacement of HX in reflector system



<Reflector Heat Exchanger>

- ✓ A few leakage events occurred on the secondary side of the heat exchanger
- ✓ After each leakage incident, the heat exchanger was further tightened to prevent additional leaks
- ✓ Eventually, tightening reached the minimum allowable stacking thickness, making further tightening no longer possible


Reflector System Overview

2



Reflector System Overview

» Positional Overview of Reflector System



- ✓ Reflector room is maintained in a sealed condition
- ✓ RCI is maintained at a lower negative pressure than RX
- ✓ During maintenance, the reflector room must be opened and the negative pressure in the RCI can no longer be maintained
- ✓ Tritium management is essential during heat exchanger replacement

Preparation and Set-up

- Integrity of Spare Plates
- Mock-up Training
- Tritium Release Assessment
- Internal Exposure Estimation

Preparation and Set-up

» Preparation of spare plates

- ✓ Visual Inspection and Hydraulic pressure tests on spare plates

» Mock-up training


- ✓ Disassembly and Removal of Existing Plates
- ✓ Installation and Reassembly with New Plates
- ✓ Estimate of Operation time and Potential Process water spill

Preparation and Set-up

» Tritium Release Assessment

✓ Evaluation Assumptions

1. All tritium exists in the form of tritiated water vapor (HTO) in air
2. 21% of tritium in the RCI migrates into the RX
3. Continuous spillage of heavy water during HX replacement



Q : Airflow rate through the reflector room

V : Volume of RCI (or RX)

c_1 : Initial tritium conc. in air

E : Increase in airborne tritium due to evaporation

c : Tritium concentration released through stack

Preparation and Set-up

» Tritium Release Assessment

Time(t, hr)	Release to the RX stack		Release to the RCI stack	
	Concentration (Bq/m ³)	Cumulative release(Bq)	Concentration (Bq/m ³)	Cumulative release(Bq)
DRL	5.07E+07	6.25E+13	3.92E+08	6.25E+13
0	1.00E+03	0.00E+00	1.00E+05	0.00E+00
0.5	7.21E+04	5.51E+08	9.21E+06	1.63E+10
1	1.27E+05	2.00E+09	1.02E+07	3.32E+10
2	1.68E+05	4.15E+09	1.03E+07	5.01E+10
4	2.68E+05	2.07E+10	1.03E+07	1.35E+11
6	3.00E+05	5.42E+10	1.03E+07	2.71E+11
8	3.03E+05	7.16E+10	1.03E+07	3.39E+11
12	3.04E+05	8.91E+10	1.03E+07	4.07E+11
24	3.04E+05	1.24E+11	1.03E+07	5.42E+11

The Derived Release Limit (DRL) represents a calculated threshold for tritium emissions, derived by back-calculating from the permissible dose to members of the public in the unrestricted area. The estimated release level was lower than this limit.

Preparation and Set-up

» Estimate of Internal Exposure

- ✓ Tritium concentration in the reflector room exceeds 100 DAC
- ✓ Positive-pressure full-body suit are required for all work
- ✓ Internal exposure was estimated based on past maintenances
- ✓ Estimated internal dose per worker : $\sim 10 \mu\text{Sv}/8\text{hr}$

MRV5 STANDARD
PINK



MRV5 STANDARD
NATURAL



Replacement Operation

4

- Replacement Workflow
- Unexpected Tritium Contamination

Replacement Operation


» Replacement Workflow

- ✓ DAY 1 : Isolate/drain secondary cooling water and heavy water
- ✓ DAY 2 : Disassemble, replace 79 plates, reassemble
- ✓ DAY 3 : Refill cooling and heavy water
- ✓ DAY 4 : Pressurization test and leak inspection



Replacement Operation

» Unexpected Tritium Contamination




✓ Incident Overview

- Prior to refilling the heavy water, the secondary side was filled first
- Unexpected tritium was detected in the secondary-side water
- Tritiated air from the reflector room entered the secondary side through the vent valve during the initial drainage process

Replacement Operation

» Unexpected Tritium Contamination



- ✓ **Corrective actions**
 - Secondary side was flushed twice to remove tritium
 - Connected extension hose to vent valve to intake clean air and prevent tritium re-contamination
 - Tritium concentration reduced to normal levels
- ✓ Airborne tritium can easily dissolve into surface moisture, so this must be considered during the work

Results

- System Integrity and Performance
- Tritium Release
- Worker Radiation Exposure

Results

» System integrity and performance

- ✓ No leakage was observed
- ✓ Normal heat exchange efficiency was verified through system operation
- ✓ No tritium was detected on the secondary side

열교환기 보수

HANTAP-05-OD-ROP-MA-03, 개정번호 7, 20/21

반사체 냉각계통 점검(원프, 밸브, 압력측정기, 열교환기), HANTAP-05-OD-ROP-PI-04-06, 개정번호 5, 7/11

붙임 6. 반사체 냉각계통 열교환기 누수시험 점검표(개정7)

반사체 냉각펌프 열교환기 누수시험 점검표					
1. 반사체 냉각펌프 기동시험					
내용	기준	초기	20분 후	40분 후	60분 후
유량	39~47.6 kg/s	45.1 kg/s	45.2 kg/s	45.1 kg/s	45.0 kg/s
원프 입/출구 압력(개정7)	414~506 kPag(출구)(개정7)	440 kPa	440 kPa	440 kPa	440 kPa
2. 반사체 냉각계통 열교환기 누수 발생유무					
생유무		없음	없음	없음	없음
점검자 서명/날짜		2024. 7. 29	이정호	이정호	이정호

REVIEWED
WITNESSED
KAERI KIM SUI YOUNG
2024. 7. 29

붙임 2. 원프 점검 기록지

원프 점검 기록지																					
계통 명칭	반사체 냉각계통(321)				원프 번호	321-P01															
점검 일자	2024. 7. 31																				
점검 항목	단 위	기 준 값				측 정 값															
회전수	RPM	3550±5% 이내(3373~3728)				3575															
입구 압력	kPag	-				-															
출구 압력	kPag	460±10% 이내(414~506)				445															
유 량	L/sec	43.3±10% 이내(39~47.6)				45.1															
제3원프 번호	321-V003																				
점검 결과 (원프, 밸브)	양호																				
구 분	I			II			III			IV											
	H	V	A	H	V	A	H	V	A	H	V										
	1.5	1.7	2.0	1.7	2.1	2.0	2.2	1.4	1.3	1.5	1.3										
	진동 기준값(㎎/s) 양호: 4.0mm/s 이하																				
배여량 온도	31.4			50			47.9			37.0											
기온값	상세 75도 이하																				
유량원 상태	양호																				
종합평가	정상작동 특이사항 없음																				

REVIEWED
WITNESSED
KAERI YUN HUI YOUNG
2024. 7. 29

Count Conditions

Nuclide: 3H

Quench Indicator: tSIE/AEC

External Std Terminator (sec): 0.5 2s

Pre-Count Delay (min): 0.00

Quench Set:

Low Energy: 3H

Count Time (min): 30.00

Count Mode: Normal

Assay Count Cycles: 1

#Vials/Sample: 1

Repeat Sample Count: 1

Calculate % Reference: Off

Background Subtract

Background Subtract: Off

Low CPM Threshold: Off

2 Sigma % Terminator: Off

Regions

	LL	UL
A	0.0	18.6
B	2.0	18.6
C	0.0	0.0

Count Corrections

Static Controller: On

Colored Samples: Off

Coincidence Time (nsec): 18

Luminescence Correction: Off

Heterogeneity Monitor: Off

Delay Before Burst (nsec): 75

Cycle 1 Results

S#	Count Time	CPMA	DPM1	Eff Nucl In A	A:2S%
1	30.00	1038	2232	46.49	1.13
2	30.00	1057	2272	46.51	1.12

DPMT Wtr
Re-Hx 2nd

Results

» Tritium Release and Public Dose

- ✓ Total tritium release: < 0.06% of daily release limit
- ✓ Peak concentration: < 0.5% of limit at both RX and RCI stacks
- ✓ Public dose: only 0.02% of the annual legal dose limit

Table 2 Daily Tritium Release: Actual, Estimated, and Limit Values

	RX		RCI		Total
	Peak conc. (Bq/m ³)	Cumulative release(Bq)	Peak conc. (Bq/m ³)	Cumulative release(Bq)	Cumulative release(Bq)
Day 1	3.75E04	2.80E09	1.41E06	6.23E10	1.43E11
Day 2	2.40E05	3.17E10	1.77E06	4.64E10	
Estimate	3.04E05	6.16E11	1.03E07	2.44E12	3.06E12
Limit	5.07E07	6.25E13	3.92E08	6.25E13	-

Results

» Worker Radiation Dose

- ✓ Max internal dose (most exposed worker): < 0.08 mSv
- ✓ Average internal dose: < 0.06 mSv
- ✓ Average total dose per worker (internal + external): < 0.06 mSv
- Although the levels are slightly higher than expected, they include all exposure accumulated during the preparation stage
- Moreover, the dose is still far below the annual exposure limit for radiation workers

Conclusion

6



Conclusion

» Technical Outcome

- Heat exchanger replacement was completed without leakage
- System performance and efficiency remained stable

» Radiological Safety

- Tritium release was well below regulatory limits, public dose was negligible
- Average worker dose stayed below 0.06 mSv

» Operational Insight

- An unexpected tritium ingress was promptly identified and resolved
- Highlighted the importance of air management and pre-planning for tritium safety

THANK YOU

[wtlee@kaeri.re.kr](mailto:wtleee@kaeri.re.kr)